

**Report of the O.A.A.A. Built Environment Subcommittee – May 9, 2024**

The O.A.A.C. Built Environment Subcommittee respectfully reports to the Oshawa Accessibility Advisory Committee its Seventh Report.

Site Plan Approval Application for the 374 Farewell Street (BUILT-24-04)

1. That details of the materials used for all paths of travel be identified and designed as per Oshawa Accessibility Design Standards (O.A.D.S.); and,
2. That all paths of travel width be labelled and the clear path of travel of a minimum of 1800 mm is provided; and,
3. That reasonable lighting levels, light should be provided at or beside all ramps, steps and stairs and evenly distributed along the path of travel. Consideration should be given to providing supplementary lighting to highlight wayfinding. Please ensure that lighting fixtures or posts do not encroach in the accessible path of travel; and,
4. That all front entrances be accessible to accommodate a wheelchair and designed as per O.A.D.S.